



Bangalore Electricity Supply Company Limited

(CIN-U4010KA2002SGC030438)

Ref. No. :BESCOM/D(T)/GM(M&C)/2023-24/2189
Encl:

Corporate Office,
BESCOM, K.R. Circle,
Bangalore-560 001.
Date: 25/01/2024

Clarification No.-1

Sub: Providing, Releasing, Fixing, Wiring and Replacement of existing Electromechanical Meters by DLMS Compliant LT AC single Phase 5-30 A and LT AC Three Phase 5-30A Electrostatic meters of class-1.0 accuracy with deep drawn meter protection box to be used sparingly only wherever required and shifting of meters from inside to outside premises wherever necessary in BRAZ and CTAZ area of BESCOM on total turnkey basis.

- Ref:** 1. Paper Notification dated 21.12.2023.
2. T.O. Bid Enquiry No. BESCOM/GM(M&C)/128/EM2ES/BRAZ/2023-24 & and BESCOM/GM(M&C)/129/ EM2ES/CTZ/2023-24.
3. KPP portal tender no: BESCOM/2023-24/EL/WORK_INDENT51 & BESCOM/ 2023-24/EL/WORK_INDENT47
4. Pre-bid meeting held on 08.01.2024.

* * * * *

The following clarification pertaining to subject bid enquiry is herewith issued consequent to request from the prospective bidders and deliberations during pre-bid meeting:

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications						
1	Instructions To Tenderers (ITT): 3. Qualification of the Tenderer: 3.2.A. Technical Requirements Clause 3: The tenderer should have executed 80% of tendered quantity of below works in any one year during the last Five Years. (i.e., FY 2018-19 to 2022-23) to any DISCOMs/ power utilities/ SEBs/ government entities in India on TTK/PTK basis: a) Replacement of Electromechanical meters by Electrostatic meters	The tenderer should have executed 80% of tendered quantity of below works in any one year during the last Five Years. (i.e., FY 2018-19 to 2022-23) to any DISCOMs/ power utilities/ SEBs/ government entities in India on TTK/PTK basis: a) Please clarify whether the work done of replacement of any kind of meter is considered or only the work done of meter whose technical specifications is uploaded in the tender (single phase /three phase 5-30A	The tenderer should have executed 80% of tendered quantity of below works in any one year during the last Five Years. (i.e., FY 2018-19 to 2022-23) to any DISCOMs/ power utilities/ SEBs/ government entities in India on TTK/ PTK basis: a) Replacement of Electromechanical meters by LT AC Single phase/ Three phase 5-30A Electrostatic meters <table><tr><th>Zone</th><th>Qty. in Nos.</th></tr><tr><td>BRAZ</td><td>2,38,346</td></tr><tr><td>CTAZ</td><td>1,61,843</td></tr></table> b) Fixing of deep drawn	Zone	Qty. in Nos.	BRAZ	2,38,346	CTAZ	1,61,843
Zone	Qty. in Nos.								
BRAZ	2,38,346								
CTAZ	1,61,843								

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications																		
	<table><tr><td>Zone</td><td>Qty. in Nos.</td></tr><tr><td>BRAZ</td><td>2,38,346</td></tr><tr><td>CTAZ</td><td>1,61,843</td></tr></table> b) Fixing of meter box. <table><tr><td>Zone</td><td>Qty in Nos.</td></tr><tr><td>BRAZ</td><td>1,19,173</td></tr><tr><td>CTZ</td><td>80,922</td></tr></table>	Zone	Qty. in Nos.	BRAZ	2,38,346	CTAZ	1,61,843	Zone	Qty in Nos.	BRAZ	1,19,173	CTZ	80,922	Electrostatic meters). b) Please clarify whether the work done of fixing of any kind of meter box is considered or only the work done of meter box/ enclosure whose technical specifications is uploaded in the tender (DDMB Boxes).	metal meter box. <table><tr><td>Zone</td><td>Qty in Nos.</td></tr><tr><td>BRAZ</td><td>1,19,173</td></tr><tr><td>CTZ</td><td>80,922</td></tr></table>	Zone	Qty in Nos.	BRAZ	1,19,173	CTZ	80,922
Zone	Qty. in Nos.																				
BRAZ	2,38,346																				
CTAZ	1,61,843																				
Zone	Qty in Nos.																				
BRAZ	1,19,173																				
CTZ	80,922																				
Zone	Qty in Nos.																				
BRAZ	1,19,173																				
CTZ	80,922																				
2	Instructions To Tenderers (ITT): 3. Qualification of the Tenderer: 3.2.A. Technical Requirements Clause 4: The tenderer should possess valid Class-1 Electrical contractor license issued by GoK.	The tenderer should possess valid Class-1 Electrical contractor license issued by GoK but has other state Electrical authority licence then tenderer should submit Class-1 Electrical contractor license issued by GoK within 15 days from the date of opening of price bid. If not the tenderer's bid will be rejected.	The tenderer should possess valid Class-1 Electrical contractor license issued by any State Electrical Authority of India or Class-1 Electrical contractor license issued by GoK. Documents to be uploaded by the Tenderer: A valid Class-1 Electrical contractor's license issued by any State Electrical Authority of India or Class-1 Electrical contractor license issued by GoK.																		
3	Instructions To Tenderers (ITT): 3. Qualification of the Tenderer: 3.2.A. Technical Requirements Clause 5: Bid Capacity (as on date of bid submission): Bidders who meet the above specified minimum qualifying criteria, will only be qualified, if their available tender capacity is more than the total tender value. The available tender capacity will be calculated as under: Assessed available tender capacity = (A*N*1.5 - B) where	Bid Capacity (as on date of bid submission): Bidders who meet the above specified minimum qualifying criteria, will only be qualified, if their available tender capacity is more than the total tender value. The available tender capacity will be calculated as under: Assessed available tender capacity = (A*N*1.5 - B) where A = Maximum value of works executed in any one year during the last five years (Price updated to present year) taking	Tender conditions prevails.																		

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
	A = Maximum value of works executed in any one year during the last five years (Price updated to present year) taking into account the completed as well as works in progress. N = Number of years prescribed for completion of the works for which tenders are invited. B = Value, of existing commitments and on-going works to be completed during the next Two years (period of completion of the works for which Tenders are invited)* Note: The statements showing the value of existing commitments and on-going works as well as the stipulated period of completion remaining for each of the works listed should be countersigned by the Employer in charge, not below the rank of an Executive Engineer or equivalent. The bidder shall upload statements showing: 1) For A: the value of works executed in any one year during the last five years, attach certificate from Chartered accountant. The details shall be filled as per Section-3 QI. 2) For B: the value of existing commitments and on-going works as well as the stipulated period of completion remaining for each of the works listed should be countersigned by the Employer in charge, not below the rank of an	into account the completed as well as works in progress. N = Number of years prescribed for completion of the works for which tenders are invited. B = Value, of existing commitments and on-going works to be completed during the next Two years (period of completion of the works for which Tenders are invited)* Note: The statements showing the value of existing commitments and on-going works as well as the stipulated period of completion remaining for each of the works listed should be countersigned by the Employer in charge, not below the rank of an Executive Engineer or equivalent or by Chartered accountant. The bidder shall upload statements showing: 1) For A: the value of works executed in any one year during the last five years, attach certificate from Chartered accountant. The details shall be filled as per Section-3 QI. 2) For B: the value of existing commitments and on-going works as well as the stipulated period of completion remaining for each of the works listed should be countersigned by the Employer in charge, not below the rank of an Executive Engineer or equivalent or by	

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
	Executive Engineer or equivalent. The details shall be filled as per Section-3 QI.	Chartered accountant. The details shall be filled as per Section-3 QI.	
4	Instructions To Tenderers (ITT): 3. Qualification of the Tenderer: 3.2.B Financial Requirements: Clause 7: The Liquid assets and or availability of credit facilities of the tenderer should not be less than ₹ 22.68 Crores (18.75% of amount put to tender) as on date of NIT or later before submission of bid consisting of cash at Bank + availability of fund-based credit facility in any Nationalized/scheduled commercial Bank.	The Liquid assets and or availability of credit facilities of the tenderer should not be less than 10% of amount put to tender as on date of NIT or later before submission of bid consisting of cash at Bank + availability of fund-based credit facility in any Nationalized/scheduled commercial Bank.	Tender condition prevails.
5	Instructions To Tenderers (ITT): 3. Qualification of the Tenderer: 3.2.C.General requirements: Clause 8: Tenderer should fulfil all the requirements and the technical specifications of energy meters stipulated in the GoK order No.EN-27 VSC 2019 Dated: 11.02.2019 and should adhere to technical specifications/ requirements of meter box. Documents to be uploaded: All the supporting documents shall be uploaded w.r.t technical requirements and the technical specifications of GoK order No.EN-27 VSC 2019 Dated: 11.02.2019 and all the supporting documents shall be uploaded w.r.t	a. The Bidders has to obtain and submit the Consent Letter from the approved vendors or retail outlet vendors of energy meters in BESCOM along with the latest type test reports. b. The successful bidder has to obtain that approval for GTPs and drawings of deep drawn meter boxes from GM(QS&S), BESCOM before the issue of DWA. As per tender documents Meter supplier/ Manufacturer is to submit all technical and financial supporting documents as per GoK order No.EN-27 VSC 2019 Dated: 11.02.2019. But the said order is only for the supply of	Tenderer should fulfil all the requirements and the technical specifications of energy meters stipulated in the GoK order No.EN-27 VSC 2019 Dated: 11.02.2019 and should adhere to technical specifications/ requirements of meter box. Documents to be uploaded by the Tenderer: All the supporting documents shall be uploaded w.r.t technical requirements and the technical specifications of GoK order No.EN-27 VSC 2019 Dated: 11.02.2019 and all the supporting documents shall be uploaded w.r.t technical specifications/ requirements of deep drawn metal meter box as specified. However, from retail outlet vendors of BESCOM Consent Letter along with the latest type test reports, ISO 9001/ 9002/ 14001 certificates, 'S' Mark certificates for 5-30A energy meters issued by STQC shall

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
	technical specifications/requirements of meter box as specified.	meters. But above said tender is Supplying and replacing (Work contract) of Meters, hence the supplier's financial details are not required, only submitting the type test certificate & and GTP Drawings of the meter and meter Box should be sufficient.	be uploaded.
6	Instructions To Tenderers (ITT): 3. Qualification of the Tenderer: General Conditions Clause 3.3.(b). Deep drawn meter boxes must be supplied by the techno-commercial responsive bidder which is required to be approved by the GM (QS&S), BESCOM for ascertaining compliance with defined parameters. After confirmation for compliance from GM (QS&S), the price bid of such bidders shall be opened.	This Clause should be deleted OR Should be amended as deep drawn meter boxes and sample meter must be supplied and obtain compliance from concerned department of BESCOM before issue of LOI.	Deep drawn meter boxes must be supplied by the techno-commercial responsive bidder which is required to be approved by the GM (QS&S), BESCOM for ascertaining compliance with defined parameters. After confirmation for compliance from GM (QS&S), DWA will be issued.
7	Instructions To Tenderers (ITT): 3. Qualification of the Tenderer: General Conditions Clause 3.3.(c). Two meters each for single phase and three phase, must be provided by the techno-commercial responsive bidders, which is required to be tested at MT Lab of BESCOM for ascertaining compliance with defined parameters. After confirmation for compliance from MT lab, the price bid of such bidders shall be opened.		Two meters each for single phase and three phase, must be provided by the techno-commercial responsive bidders, which is required to be tested at MT Lab of BESCOM for ascertaining compliance with defined parameters. After confirmation from MT Lab DWA will be issued.

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
8	Section-8 Bill of Quantities. The quantity of accessories such as PVC pipe, PVC bend, Aluminium wire, etc. are mentioned as Lump sum.	The quantity of accessories such as PVC pipe, PVC bend, Aluminium wire, etc. should be taken as per actual quantity of materials consumed at site location	Request will be reviewed based on the survey reports submitted by the successful bidder.
9	F. Special Conditions of Contract (SCC): Clause 15.1: Scope of the work includes: (ix) Release of all existing EM/High precision meters. After certification of Final reading (FR) from concerned section officer, the authorized representative of the firm shall safely return the released Electro mechanical/High Precision meters to concerned C, O&M divisional stores within two days from the date of release report by duly collecting acknowledgement receipts from divisional stores, in case of three phase meters after rating by MT staff.	We request you to introduce the buyback scheme for the released meters. The released EM meter is returned to the Store and it will take too much time to take the Indent from the O&M Office and submit the meter to the Division Store then we will get the ACK will affect to progress of the project, which we request to buyback the EM meters	Tender condition prevails.
10	Instructions To Tenderers (ITT): Clause-4 One Tender per Tenderer: 4.1. The tenderer can participate in both the tender enquiries. Limitation of issue of "DWA" shall be restricted to maximum one for one bidder. However to avoid dependencies, the contract order of	This Clause has to be deleted as there Should not be any restriction/ limitation to obtain more than one tender as per KW-4 of KTPP Act.	Tender condition prevails.

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications						
	more than one tender enquiry is at the discretion of BESCOM.								
11	F. Special Conditions of Contract (SCC): Clause 15.1:Scope of the work includes: xi) Fixing of new suitable Electrostatic (ES) meters in place of existing EM / high precision meters with meter box wherever necessary. Shifting of meters from inside to outside the premises shall be carried out wherever necessary.	Shifting of meters from inside to outside the quantity of accessories given in the estimate is very less it is impossible to shift the meter, kindly make the accessories according to site requirement and how much quantity used in the site.	Request will be reviewed based on the survey reports submitted by the successful bidder.						
12	F. Special Conditions of Contract (SCC): Clause 18.11. Collection of disposal cost of materials used made of FRP/ PLASTIC/SMC and Polymer material used as per the circular issued by BESCOM vide OM No: BESCOM/GM(Q,S&S)/DGM(3)/MGR/BC-35/18-19/CYS-109 Dated: 03.09.2019 consequent to the direction issued by NGT/pollution control board. The cost is worked out by collecting information from meter manufacturers, hence following amount will be deducted from the tenderer as disposal cost: <table border="1"><tr><th>Type of meter</th><th>Disposal cost in</th></tr><tr><td>Single phase</td><td>Rs.1.00 per meter</td></tr><tr><td>Three phase</td><td>Rs.2.00 per meter</td></tr></table>	Type of meter	Disposal cost in	Single phase	Rs.1.00 per meter	Three phase	Rs.2.00 per meter	It is not included in the Estimate or loading factor and also it is not mentioned in the present SR. So please remove the clause from bidding documents.	Disposal cost is included in the estimate.
Type of meter	Disposal cost in								
Single phase	Rs.1.00 per meter								
Three phase	Rs.2.00 per meter								
13	Instructions To Tenderers (ITT): Clause 29: Security deposit / Contract Performance Guarantee: 29.1 Within 20 days of	Within 20 days of receipt of the Letter of Acceptance, the successful Tenderer shall submit a Security Deposit / Contract	Tender condition prevails.						

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
	receipt of the Letter of Acceptance, the successful Tenderer shall deliver to BESCOM a Security Deposit / Contract Performance Guarantee in the form of Bank Guarantee for an amount equivalent to 5% of the Contract price.	Performance Guarantee to BESCOM in the form of Bank Guarantee for an amount equivalent to 3% of the Contract price.	
14	Instructions To Tenderers (ITT): Clause 3.3 General Conditions: a) Completion period is considered as 18 months and 16 months is considered as actual execution period.	Period of completion shall be considered 24 months from the date of DWA, because 80% of the project area is covered under rural and remote places, hence Too much time and effort is required to make the survey and preparation of estimate, work order/ Award and shifting of materials, replacement of the meters. Kindly consider the request to extend the completion period.	Tender condition prevails.
15	Technical requirements Clause no.8. 'S' mark safety certification for single Phase (5-30A) and three phase whole current (5-30A) energy meters manufacturing in India issued by STQC.	We would like to inform you that, BIS license (ISI logo) as per IS: 13779 is Mandatory requirement for energy meters All minimum safety parameters (like insulation, clearance-creep age, glow wire, heating, self-heating, STOC, IP, marking req. etc.) are already covered in above mentioned product standards. BIS certification ensure about compliance of energy meters against that safety parameters. 'S' Mark scheme (Safety Certification) of STQC is intended to provide adequate level of confidence regarding safety of product. It should be mandatory for	Tender condition prevails.

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
		household Appliances, consumer electronics, electronic toys etc., which are handheld items, to ensure the human safety. Hence 'S' Mark certification is not mandatory. <u>Global scenario (for reference):</u> All safety-related parameters/tests have been removed from Edition 2 of IEC product standards (IEC 62052-11, IEC 62053-21 /22 /23 /24) and the safety tests are now covered in the new safety standard (specific to energy meters) IEC 62052-31. We believe that these new series of IEC standards are practice in all the utilities. We trust that you will appreciate the concern and look into our request and make the "S" mark as optional and not mandatory it could be very much helpful to amend the requirement for the 'S' mark certification in the above referred tender specification.	
16	Technical specifications single phase meters: Clause No.5.7 Communication Capability: The meter shall be ICS (Indian Companion Specification) compliant as per IS 15959: 2011 with latest amendments. The meter shall have provision of a galvanically isolated optical port to download the data locally	In offered meter additional communication port RS 232 in form of Micro USB suitable for interference with external modem for remote reading is provided. Please accept the same.	Tender condition prevails.

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
	through CMRI. This port shall also be used for remote data reading through modem. An additional RS232 port, in the form of physical interface connector RJ-11 which shall be used for remote meter data acquisition remotely through PSTN / Optical fiber / GSM / GPRS / CDMA / PLCC / LPR communication medium Rs232 port provided shall be galvanically isolated internally and terminated on RJ 11 connector. It shall not be possible to re-programme or make any change in the meter through CMRI.		
17	Technical specifications single phase meters: Clause No.5.7 Communication Capability v. Optical port of the meter shall be provided with a suitable covered sealing arrangements having no physical access from outside without breaking the seal Rs232 port should be provided under the terminal cover so that it cannot be accessed without opening the terminal cover Rs232 shall have suitable sealing facility.	In the offered meters are provided with software lock feature, reading cannot be done without authentication, sealing is not required at the optical port & RS 232. Please accept the same.	Tender condition prevails.
18	Technical specifications single phase meters: Clause No. 5.14 LED / LCD Indications LEDs /LCD shall be provided for following	The offered meter will have separate icon for Magnet, ND & Earth load/current unbalance events only, it will remain on LCD display till meter reading subject to	Tender condition prevails.

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
	indications: a.LED for Test output pulse (Imp/kwh) - Red b.Icon on LCD for load earthing c.Icon on LCD for current reversal d.Icon on LCD for neutral missing e.Icon on LCD for magnetic tamper f. Icon on LCD for phase available g.Icon on LCD for Meter Cover Open	restoration of display. Earth Load/Current unbalance:  Magnet: -  Neutral Disturbance  For all supported tamper, suitable abbreviation/information will be provided under below display parameters:- Present current related tamper status Present other than current and voltage tamper status Present voltage related tamper status In additional to above, offered meter have provision to display last occurred tamper with its date & time and last restored tamper with its date & time. We request you to consider the same.	
19	Technical specifications single phase meters: Clause No.11.1.a and three phase meters as per Clause No.12.1 a. Type test as per IS 13779 The type test certificates for all tests as per IS 13779 - 1999 (with latest amendments) shall be uploaded along with the bid. Type test certificates from any one of the standard	Test certificates from standard laboratories such as CPRI/ERDA/NPL/ERTL/any NABL accredited lab shall be considered.	Tender condition prevails.

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
	Laboratories such as CPRI/ERDA/ NPL/ ERTL shall only be considered. The type test certificates shall not be older than 5 years as on the date of NIT. In absence of these type test reports, offer shall be rejected out rightly. Type tests should be conducted on meter having similar constructional and other features.		
20	Name of work: Providing, Releasing, Fixing, Wiring and Replacement of existing Electromechanical Meters by DLMS Compliant LT AC single Phase 2 wire 5-30 A and LT AC Three Phase 4 wire 5-30A Electrostatic meters of class-1.0 accuracy with deep drawn meter protection box to be used sparingly only wherever required and shifting of meters from inside to outside premises wherever applicable on total turnkey basis in BRAZ area of BESCOM on PERCENTAGE QUOTING BASIS.	10-100A is a higher and better rating than 5-30A. Kindly accept the same.	Tender condition prevails.
21	Technical specifications single phase meters: Clause No.5.4.b.ii. PUSH BUTTON DISPLAY The following parameters shall be displayed, one after other, with press of push button each time. The display shall have suitable display time for each measured values, except the LCD segment check, which shall have	Offered meter will have 2 modes for display i.e. Auto mode & Push button mode. Therefore, High resolution display will be provided in manual mode. Offered meter having the following provisions; Display on time in Manual mode 1 min. Display on time in Auto	Tender condition prevails.

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
	display of 2 seconds. There shall be two push buttons one for forward scrolling and the other for reverse scrolling of parameters.	mode 10 sec. Display off time Auto mode 0 sec. We request you to consider the same.	
22	Technical specifications Three phase meters: Clause No.5.8 Communication Capability: The meter shall be ICS (Indian Companion Specification) compliant as per IS 15959:2011 with latest amendments. The meter shall have provision of a galvanically isolated optical port to download the data locally through CMRI. This port shall also be used for remote data reading through modem. An additional RS232 port, in the form of physical interface connector RJ-11 which shall be used for remote meter data acquisition remotely through PSTN/Optical fiber / GSM / GPRS / CDMA / PLCC / LPR communication medium. RS 232 port provided shall be galvanically isolated internally and terminated on RJ 11 connector. It shall not be possible to re-programme or make any change in the meter through CMRI.	Offered meter have communication port RS 232 in the form of RJ 45. Please accept the same.	Tender condition prevails.
23	Technical specifications Three phase meters: Clause No.5.8 Communication Capability:	In the offered meters are provided with software lock feature, reading cannot be done without authentication,	Tender condition prevails.

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
	v. Optical port of the meter shall be provided with a suitable covered sealing arrangement having no physical access from outside without breaking the seal. RS232 port should be provided under the terminal cover so that it cannot be accessed without opening the terminal cover. RS232 shall have suitable sealing facility.	sealing is not required at the optical port & RS 232. Please accept the same.	
24	F. Special Conditions of Contract (SCC): Clause 15.1:Scope of the work includes: vi) The successful bidder shall handover new ES meters to BESCOM MT lab for accuracy test and for sealing of meters.	The Quantity of the meters is very high, hence testing & making the sealing at site it take very long time. So we request you to make the sealing in factory only.	F. Special Conditions of Contract (SCC): Clause 15.1:Scope of the work includes: vi) The successful bidder shall handover new ES meters to BESCOM MT lab for accuracy test as per Standards. The meter cover of the meter shall be sealed at the factory premises of the meter manufacturer as per BESCOM approved specification.
25	F. Special Conditions of Contract (SCC): Clause 15.2: The detailed scope of the works shall include but not limited to the following: 7. The MT lab shall test the accuracy and seal the meters as per prevailing standards of BESCOM.	-	F. Special Conditions of Contract (SCC): Clause 15.2: The detailed scope of the works shall include but not limited to the following: 7. The MT lab shall test the accuracy of meters as per Standards.
26	F. Special Conditions of Contract (SCC): Clause 15.2: The detailed scope of the works shall include but not limited to the following: 8. The successful bidder shall collect the sealed meters from MT lab and execute the works as per the	-	F. Special Conditions of Contract (SCC): Clause 15.2: The detailed scope of the works shall include but not limited to the following: 8. The successful bidder shall procure required quantity of numbered polycarbonate seals with sealing wire at the cost of the bidder as per BESCOM

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
	contract.		approved specifications and drawing which are to be used for sealing of meters and also the meter cover of the meter shall be sealed at the factory premises of the manufacturer and execute the works as per the contract.
27	F. Special Conditions of Contract (SCC): Clause 35.1.1 Payments Against Supply: a) Fifty percent (50%) of the ex-works plus 100% taxes including Freight and levies of the MT sealed ES Meters, meter box wherever applicable and other miscellaneous materials (applicable as per the terms of contract) on receipt (after supply of turnkey materials) shall be paid subject to the Certification by the AEE of concerned SDO and EE of concerned Division Office with submission of the following: i) Copy of the certificate of Transit and Storage Insurance. ii) Pre-dispatch clearance certificate issued by the BESCOM, prior to dispatch of the consignment. iii) Contractor's detailed invoice. iv) Packing list/Bill of materials. v) Delivery Instructions issued from Corporate office. vi) The ES meters shall be sealed from MT lab of BESCOM and	Requested for deletion of the Point vi) of Clause 35.1.1.	F. Special Conditions of Contract (SCC): Clause 35.1.1 Payments Against Supply: a) Fifty percent (50%) of the ex-works plus 100% taxes including Freight and levies of the sealed ES Meters, meter box wherever applicable and other miscellaneous materials (applicable as per the terms of contract) on receipt (after supply of turnkey materials) shall be paid subject to the Certification by the AEE of concerned SDO and EE of concerned Division Office with submission of the following: i) Copy of the certificate of Transit and Storage Insurance. ii) Pre-dispatch clearance certificate issued by the BESCOM, prior to dispatch of the consignment. iii) Contractor's detailed invoice. iv) Packing list/Bill of materials. v) Delivery Instructions issued from Corporate office. vi) The ES meters shall be sealed at the factory premises of the meter manufacturer and the same shall be certified by BESCOM officer deputed for inspection of particular lot of meters at the factory premises of the meter manufacturer

Sl. No.	As existing Clause No.	Clarifications/amendments sought by the firm	BESCOM Clarifications
	reports for the same certified by Assistant Executive Engineer of MT Laboratory.		

All other terms & conditions of the subject tender remain unaltered.


(Yogesh.B.K)
General Manager (Ele.),
Meters & Commercial
BESCOM